

This matter is being dealt with by:
Ross Marshall
T 0115 9774473
E ross.marshall@nottscc.gov.uk



Planning ref:
V/2025/0003
Consultation received:
1/28/2025

Ms Cristine Sarris
Planning and Building Control Manager
Ashfield District Council
Head Office
Urban Road
Kirkby-in-Ashfield
NG17 8DA

17 February 2025

Dear Ms Sarris

PROPOSAL: Development of a drive-thru restaurant (use class e/sul generis) with associated access, servicing, car parking, hard and soft landscaping and other associated works

LOCATION: Lane End, Kirkby In Ashfield

Nottinghamshire County Council as the Lead Local Flood Authority (LLFA) has reviewed the application which was received on the 1/28/2025. Based on the submitted information we have no objection to the proposals and can recommend approval of planning subject to the following conditions;

Condition

No part of the development hereby approved shall commence until a detailed surface water drainage scheme based on the principles set forward by the approved Flood Risk Assessment (FRA) and Drainage Strategy ST2120, 10th January 2025, has been submitted to and approved in writing by the Local Planning Authority in consultation with the Lead Local Flood Authority. The scheme shall be implemented in accordance with the approved details prior to completion of the development. The scheme to be submitted shall:

- Demonstrate that the development will use SuDS throughout the site as a primary means of surface water management and that design is in accordance with CIRIA C753 and NPPF Paragraph 175.
- Limit the discharge generated by all rainfall events up to the 100 year plus 40% (climate change) critical rain storm to QBar rates for the developable area.
- Provide detailed design (plans, network details, calculations and supporting summary documentation) in support of any surface water drainage scheme, including details on any attenuation system, the outfall arrangements and any private drainage assets.

Calculations should demonstrate the performance of the designed system for a range of return periods and storm durations inclusive of the 1 in 1 year, 1 in 30 year and 1 in 100 year plus climate change return periods.

- No surcharge shown in a 1 in 1 year.

The Council is committed to protecting your privacy and ensuring all personal information is kept confidential and safe. For more details see our general and service specific privacy notices at: <https://www.nottinghamshire.gov.uk/global-content/privacy>

Nottinghamshire County Council, County Hall, West Bridgford, Nottingham NG2 7QP

- No flooding shown in a 1 in 30 year.
- For all exceedance to be contained within the site boundary without flooding properties in a 100 year plus 40% storm.
- Justification for the use or not of infiltration, including the results of soakaway testing, in accordance with BRE 365.
- Provide details for exceedance flows; surface water should be contained within the site boundary without flooding any properties in a 1 in 100 year plus 40% climate change storm.
- Evidence to demonstrate the viability (e.g Condition, Capacity and positive onward connection) of any receiving watercourse to accept and convey all surface water from the site.
- Details of STW approval for connections to existing network and any adoption of site drainage infrastructure.
- Evidence of approval for drainage infrastructure crossing third party land where applicable.
- Provide a surface water management plan demonstrating how surface water flows will be managed during construction to ensure no increase in flood risk off site.
- Evidence of how the on-site surface water drainage systems shall be maintained and managed after completion and for the lifetime of the development to ensure long term effectiveness.

Reason

A detailed surface water management plan is required to ensure that the development is in accordance with NPPF and local planning policies. It should be ensured that all major developments have sufficient surface water management, are not at increased risk of flooding and do not increase flood risk off-site.

Informative

We ask to be re-consulted with any changes to the submitted and approved details of any FRA or Drainage Strategy which has been provided. Any deviation from the principles agreed in the approved documents may lead to us objecting to the discharge of conditions. We will provide you with bespoke comments within 21 days of receiving a formal consultation.

Yours sincerely

Ross Marshall

Ross Marshall

Principal Flood Risk Management Officer
Nottinghamshire County Council

Please ensure any consultations are sent to flood.team@nottscc.gov.uk